
Scotchlok® Brand Terminals

Crimp-Type

CAT. NO. MVU18-6FFB THRU MVU10-10FFB (B-12-1102 THRU D-12-1103)



Flanged Block Fork, Vinyl Insulated, Butted Seam



UNDERWRITERS LABORATORIES STANDARD NO. UL 486A 3M FILE NO. E23438



CANADIAN **STANDARDS ASSOCIATION** STANDARD NO. 22.2 NO.S 0, 65 3M FILE NO. LR22190

Wire	Stud Size	w	С	L	E	Thlok-	Berrel		Max. Wire		
(AWQ)							Length	I.D.	insul. Dia.	Catalog Number	
22- 18	6	.30	.25	.85	.70	.030	.25	.070	.145	MVU18-6FFB	(B-12-1102)
	8	.30	.25	.85	.70	.030	.25	.070	.145	MYU18-8FFB	(B-12-1103)
	10	.30	.25	.85	.70	.030	.25	.070	.145	MVU18-10FFB	(B-12-1104)
16- 14	6	.30	.25	.85	.70	.030	.25	.090	.170	MVU14-6FFB	(C-12-1102)
	8	.30	.25	.85	.70	.030	.25	.090	.170	MVU14-8FFB	(C-12-1103)
	10	.30	.25	.85	.70	.030	.25	.090	.170	MVU14-10FFB	(C-12-1104)
12- 10 (Yallow)	6	.32	.29	1.03	.84	.040	.25	.135	.250	MYU10-6FFB	(D-12-1101)
	8	.32	.29	1.03	.84	.040	.25	.135	.250	MVU10-8FFB	(D-12-1102)
	10	.32	.29	1.03	.84	.040	.25	.135	.250	MYU10-10FFB	(D-12-1103)

SPECIFICATIONS:

WIRE SIZE:

BARREL SEAM:

MAXIMUM VOLTAGE RATING:

MAXIMUM OPERATING TEMP.:

MAXIMUM CURRENT:

INSULATOR MATERIAL:

TERMINAL MATERIAL:

TERMINAL PLATING:

SEE TABLE ABOVE

BUTTED

600 Y BUILDING WIRE 1000 V SIGNS, FIXTURES

AND LUMINAIRES

105°C. 221°F

SAME AS WIRE

VINYL

ETP COPPER

TIN

INSTALLATION INFORMATION:

Caution — turn power off before installing or removing terminal. All electrical work should be done according to appropriate electrical codes.

UL Listed and CSA Certified for use on stranded copper (AWG) wire only.

Strip away the end 3/8 inch of wire insulation.

Make the crimp in the proper station of a recommended 3M crimp tool: TH-440, TH-450 (scissor style), TR-482, TR-484 (ratchet style) hand tools.



ENGINEERING SPECIFICATION:

a flat tongue portion with a central opening for mounting around a screw or stud.

The terminal line shall offer tongue variations in hole (stud) size (..., 6, 8, 10, etc.) and configuration (ring, fork, block fork, flanged block fork, locking fork, etc.): and barrel variations in wire (AWG) range (..., 22-18, 16-14, 12-10, etc.) and construction (non-insulated brazed seam, vinyl insulated butted seam, nylon insulated with insulation grip, etc.). The terminal line shall have regulatory agency coverage (UL Listing, CSA Certification). The terminal tongue shall be marked with the wire range and a manufacturer's symbol (4). Crimp-Type Terminals shall, electrically and mechanically, connect to a prestripped end of a stranded copper wire: and have

The Vinyl Insulated, Butted Seam, Flanged Block Fork terminal shall be tin plated, annealed copper, with the tongue having a specified stud slot (6, 8, 10) and with a butted seam barrel covered by a molded vinyl funnel entry sleeve, color coded and sized for a specified (AWG) wire range (Red, 22–18: Blue, 16–14: Yellow, 12–10).

Insulated terminals shall be UL Listed and CSA Certified for 600 Volts maximum, building wire: 1000 Volts maximum, in signs, fixtures and luminaires, and have a maximum operating temperature of 105°C.

important Notice: All statements, technical information and recommendations contained herein are based on tests we believe to be reliable, but the accuracy or completeness thereof is not guaranteed, and the following is made in lieu of all warranties, express or implied: Seller's and manufacturer's only obligation shall be to replace such quantity of the product proved to be defective. Neither seller nor manufacturer shall be liable for any injury, loss or damage, direct or consequential, arising out of the use of or inability to use the product. Before using, user shall determine the suitability of the product for his intended use, and user assumes all risks and liability whatsoever in connection therewith. Statements or recommendations not contained herein shall have no force or effect unless in an agreement signed by officers of seller and manufacturer.

5/87

